

NCE Environmental Consultants

January 28, 2018

Mr. Harold Simmons
Superintendent of Buildings and Grounds
Gouverneur Central School District
Gouverneur, New York 13642

Re: 2018 Fire Inspections

Dear Mr. Simmons:

I have completed the fire inspections of all the buildings in the district and the following violations were noted. It is required that these violations be corrected in order to receive a certificate of occupancy.

Gouverneur Elementary

1. Item 2E2 Rescue window blocked in room 11, 14, 52, 54.
2. Item 10A2 Exit directions missing in 1F, 6, 13.
3. Item 12E1 Appliance plugged into surge in office.
4. Item 17G1 Maximum occupancy sign missing in gym.
5. Item 17J1 Carts in hallway.

West Side Elementary - Under Construction

Senior High School

1. Item 12E1 Bad cord end on extension cord in Ag. Shop.
2. Item 17H2 Emergencylight not working in 253.
3. Item 17L1 Exit light out by 351.

36173 NYS Rt. 12E Clayton, New York 13624
315.654.5077

Bus Garage – No violations noted.

Access Center – No violations noted.

West Side Storage – Demolished

East Side Storage 1 – No violations noted.


East Side Storage 2 – Demolished

East Side Storage 3 – No violations noted.

East Side Storage 4 – No violations noted.

Please advise me as to the date of the board meeting for the presentation of this report. You need to notify the public and the fire department as to the time and date of this meeting.

Sincerely yours,

A handwritten signature in black ink that reads "John Warneck". The signature is written in a cursive style with a large, looped initial "J".

John Warneck